



California Regional Water Quality Control Board, San Diego Region

June 13, 2014

In reply refer to: 257831:lcanada

Mr. Robert Mulvey
Assistant Public Utilities Director
Water Quality Branch
City of San Diego
2392 Kincaid Road
San Diego, CA 92101

Subject:

Review of Monitoring Reports for South Bay Water Reclamation Plant

Order No. 2000-203

Mr. Mulvey:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April 2014 monthly monitoring report submitted by City of San Diego (City) in accordance with the Monitoring and Reporting Program of Order No. 2000-203.

The submitted report identified the following violation of Section A.1 (Discharge Specifications) in Order No. 2000-203:

The 30-day average effluent limitation for chloride, established at 260 milligrams per liter (mg/L), was exceeded on the days listed in the table below:

Date	Reported Value (mg/L)
April 2, 2014	270
April 8, 2014	267
April 15, 2014	264

Please take steps to implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations subject the City to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the City to cease and desist from violations, administrative assessment of civil liability in amounts of up to \$5,000 per day per violation; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

¹ Under authority of California Water Code section 13350.

The next monitoring report required to be submitted is the May 2014 monthly monitoring report, which is due by June 30, 2014.

In the subject line of any response, please include reference **257831:Icanada**. Please contact Ms. Leah Canada at 619-521-8050, or at <u>Leah.Canada@waterboards.ca.gov</u> if you have any questions or comments.

Respectfully,

John R. Odermatt, P.G., Senior Engineering Geologist Land Discharge Unit

JRO: oo: lc

Tech Staff Info & Use		
Place ID Reg. Measure ID Violation ID	257831 396699 970120 970121 970122	